



# First Group Lab

## CE LVD TEST REPORT

For  
Aldo Bernardi srl

**Model No.:** Brass Conduit system

**Applicant:** Aldo Bernardi srl  
via Vittorio Veneto, 7  
31017 Pieve del Grappa - TV - Italy

**Manufacturer:** Aldo Bernardi srl  
via Vittorio Veneto, 7  
31017 Pieve del Grappa - TV - Italy

**Issued by:** First Group sas  
via Tiepolo, 18  
31021 Mogliano V.to, Treviso, Italy  
tel.: +39 041 5951122  
mail: info@firstgroup.it

**Report number:** 02306353LN-00  
**Issued Date:** 10/07/2023  
**Start of tests:** 15/04/2023  
**End of tests:** 10/07/2023  
**Date of sample receipt:** 18/01/2023

### Note

The results reported in this test report relate the tested item only.

The laboratory is not responsible of the sampling.

This report shall not be reproduced, except in full, without the written approval of the Issuing Testing Laboratory.

| TEST REPORT<br>EN IEC 61386-21<br>Conduit systems for cable management<br>Part 21: Particular requirements - Rigid conduit system  |   |
|--|---|
| <b>Report number:</b>  | 02306353LN-00   |
| <b>Date of issue:</b>  | 10/07/2023  |
| <b>total number of pages:</b>  | 11  |
| <b>Name of Testing Laboratory preparing the Report:</b>  | First Group sas - via Tiepolo, 18 - Mogliano V.to - Treviso - Italy   |
| <b>Applicant's name:</b>   | Aldo Bernardi srl   |
| <b>Address:</b>  | via Vittorio Veneto, 7<br>31017 Pieve del Grappa - TV - Italy   |
| <b>Test specification Standard:</b>  | IEC 61386-21: 2021 used in conjunction with IEC 61386-1: 2008 + A1: 2017  |
| <b>Non standard test method:</b>   | N/A   |
| <b>Trade Mark:</b>   | Aldo Bernardi srl   |
| <b>Model/Type designation:</b>   | Brass Conduit system  |
| <b>Test Item Description:</b>  | Metallic conduit system   |
| <b>Ratings:</b>  | 1000V a.c. / 1500V d.c.   |
| <b>Possible test verdict</b>   |   |
| N/A  | test case does not apply to the test object   |
| P (pass)   | test object does meet the requirement   |
| F (fail)   | test object does not meet the requirement   |
| Decisional rule  | The judgment / declaration of conformity is assigned taking into account only the numerical values of the measurands reported in this document or the data obtained in the visual inspection. |
| <b>Tested by :</b>   | laboratory technician Valter Benetton <u>Valter Benetton</u>  |
| <b>Approved by:</b>  | laboratory manager Giorgio Lovisetto <u>Giorgio Lovisetto</u>   |
| <b>General remarks:</b>  |   |
| <p>This report includes the following parts:</p> <ul style="list-style-type: none"> <li>_ Applied clauses of IEC 61386-21.</li> <li>_ Annex 1: Tables</li> <li>_ Annex 2: Photo Documentation.</li> <li>_ Annex 3: Laboratory Equipments.</li> </ul> <p>Unless otherwise specified, test are made under normal conditions at an ambient temperature within the range of 18°C to 28°C, RH 45% to 75%.</p> <p>Throughout this report a comma is used as the decimal separator.</p> |   |

Test item particulars:

Conduit system classification coding:

|   |  |
|---|--|
| Type of conduit .....                   | <input checked="" type="checkbox"/> metallic <input type="checkbox"/> non metallic <input type="checkbox"/> composite                        |
| Type of conduit .....                   | <input checked="" type="checkbox"/> plane <input type="checkbox"/> corrugated  |
| Type of conduit fitting .....           | <input checked="" type="checkbox"/> metallic <input type="checkbox"/> non metallic <input type="checkbox"/> composite                        |
| Conduit fitting – quantity .....        | N/A  |
| Conduit fitting – type(s) .....         | <input checked="" type="checkbox"/> metallic <input type="checkbox"/> non metallic <input type="checkbox"/> composite                        |
| Conduit fitting – colour(s) .....       | N/A  |
| Method for connection .....             | <input type="checkbox"/> threadable <input checked="" type="checkbox"/> non-threadable   |
| Resistance to compression .....         | <input type="checkbox"/> light <input type="checkbox"/> medium <input checked="" type="checkbox"/> heavy <input type="checkbox"/> very heavy |
| Resistance to impact .....              | <input type="checkbox"/> light <input type="checkbox"/> medium <input checked="" type="checkbox"/> heavy <input type="checkbox"/> very heavy |
| Resistance to bending .....             | <input checked="" type="checkbox"/> rigid  |
| Electrical characteristics .....        | <input checked="" type="checkbox"/> electrical continuity <input type="checkbox"/> electrical insulating                                     |
| Resistance to external influences ..... | <input type="checkbox"/> without protection <input checked="" type="checkbox"/> with protection IP40   |
| Resistance against corrosion .....      | <input type="checkbox"/> without protection <input checked="" type="checkbox"/> with protection  |
| Resistance to flame propagation .....   | <input checked="" type="checkbox"/> no propagation <input type="checkbox"/> flame propagation  |

Classification code of brass conduit system according with Annex A of IEC 61386

- 4 Heavy compression strenght
- 4 Heavy impact strenght
- 5 -45°C lower temperature range
- 7 +400°C upper temperature range
- 1 Rigid (no bending)
- 1 With electrical continuity
- 4 Protect against solid foreign objects of 1 mm diameter and greater
- 0 No protection against ingress of water
- 2 Medium resistance to corrosion inside and outside
- 1 Very light tensile strenght

The system cover by this test report is composed by the follow elements:

- LIN.1.0** brass tube Ø20 mm
- LIN.2.0** brass tube Ø16 mm
- LIN.3.0** brass tube Ø10 mm
- CUR.1** bent brass tube Ø20 mm
- CUR.2** bent brass tube Ø16 mm
- CUR.3** bent brass tube Ø10 mm
- SUP.1** wall support in brass cast for tube Ø20 mm
- SUP.2** wall support in brass cast for tube Ø16 mm
- SUP.3** wall support in brass cast for tube Ø10 mm
- RAC.1** wall connection in brass cast for tube Ø20 mm
- RAC.2** wall connection in brass cast for tube Ø16 mm
- RAC.3** wall connection in brass cast for tube Ø10 mm
- VOL.1** brass head to head connection for tube Ø20 mm
- VOL.2** brass head to head connection for tube Ø16 mm
- VOL.3** brass head to head connection for tube Ø10 mm

| <b>IEC 61386-21</b> |   |                           |          |
|---------------------|---|---------------------------|----------|
| Clause              | Requirement + Test  | Result - Remark           | Verdict  |
| <b>7</b>            | <b>MARKING AND DOCUMENTATION</b>  |                           | <b>P</b> |
| 7.1                 | Conduit (conduit fitting) is marked on the product with a trade mark or a name identifying the manufacturer or responsible vendor .....   |                           | P        |
|                     | Conduit (conduit fitting) is marked in addition in such a way that it can be identified in the manufacturer's, or responsible vendor's, literature                              |                           | P        |
| 7.1.1               | Classification code accordance Annex A, least first four digits   |                           | P        |
| 7.1.2               | Manufacturer indicates the compatibility of parts within a conduit system   | on instruction sheet      | P        |
| 7.1.101             | Conduit is marked in accordance with 7.1 along its entire length at regular intervals of preferably 1 m but not longer than 3 m (m)   | one for item (2 m lenght) | P        |
| 7.2                 | Conduit fitting is marked in accordance with 7.1  |                           | P        |
| 7.6                 | Marking is durable and clearly legible  |                           | P        |
| <b>8</b>            | <b>DIMENSIONS</b>   |                           | <b>P</b> |
| 8.1                 | Threads and external diameter comply with IEC 60423   | see Tab 8.1 on Annex 1    | P        |
| <b>9</b>            | <b>CONTRUCTION</b>  |                           | <b>P</b> |
| 9.1                 | There are no sharp edges, burrs or surface projections within the conduit system  |                           | P        |
|                     | The manufacturer provides guidelines to assist the safe installation of the conduit system  |                           | P        |
| 9.2                 | Screws, if any, used for attaching components or covers to conduit fittings, or in joints to conduits, do not cause damage to cable insulation when correctly inserted          |                           | N/A      |
|                     | Screws have ISO metric threads  |                           | N/A      |
|                     | Thread-cutting screws are not used  |                           | N/A      |
| 9.5                 | Any material within the joint have at least the same level of resistance to the external influence as either the conduit or the conduit fitting                                 |                           | P        |
| 9.6                 | Indications whether the conduit system that are assembled by means other than threads can be disassembled and if so, how this can be achieved, are provided by the manufacturer |                           | P        |
| <b>10</b>           | <b>MECHANICAL PROPERTIES</b>  |                           | <b>P</b> |
| <b>10.1</b>         | <b>Mechanical Strenght</b>  |                           | -        |
| 10.1.1              | Conduit systems have adequate mechanical strength   |                           | P        |

|             |  |                         |     |
|-------------|--|-------------------------|-----|
| 10.1.2      | Conduits do not crack and are not deformed when bent or compressed, or exposed to impact or extreme temperature, according to their classification |                         | P   |
| 10.1.3      | Conduit systems intended as a mounting for other equipment have adequate mechanical strength   |                         | N/A |
| <b>10.2</b> | <b>Compression test</b>  |                         | P   |
|             | sample length (200 ± 5mm)  | 200                     | -   |
|             | compression force (ref table 4 ) (N)   | 1250                    | -   |
|             | force applied for 60 ± 2 sec   |                         | -   |
|             | Difference between initial outside diameter and the diameter of the flattened sample not exceed 25%  | see Tab 10.2 on Annex 1 | P   |
| <b>10.3</b> | <b>Impact test</b>   |                         | P   |
|             | 12 samples of conduit, each (200 ± 5) mm in length, or 12 samples of conduit fittings subjected to an impact test                                  | see Tab 10.3 on Annex 1 | -   |
| 10.3.3      | At least 9 of the 12 samples passed the test   | 12                      | P   |

|             |  |  |          |
|-------------|--|--|----------|
| <b>11</b>   | <b>ELECTRICAL PROPERTIES</b>   |  | <b>P</b> |
| <b>11.1</b> | <b>Electrical requirements</b>   |  | -        |
| 11.1.2      | Conduit systems of a metal or composite materials shall be so constructed that accessible metal parts can be bonded to earth |  | P        |
| 11.1.3      | Accessible conductive parts shall be effectively earthed   |  | P        |
| <b>11.2</b> | <b>Bonding test</b>  |  | -        |
|             | Resistance < 0,1 Ω (Ω)   |  | P        |

|             |  |              |          |
|-------------|--|--------------|----------|
| <b>14</b>   | <b>EXTERNAL INFLUENCES</b>   |              | <b>P</b> |
| <b>14.1</b> | <b>Degree of protection provided by enclosure</b>  |              | -        |
| 14.1.1      | Conduit systems have adequate resistance to external influences according to the classification declared by the manufacturer, with a minimum requirement of IP30 | IP40         | P        |
| <b>14.2</b> | <b>Resistance against corrosion</b>  |              | -        |
|             | Resistance to corrosion classification for painted and zinc coated steel and steel composite conduits and conduit fittings (table 10)                            | resistance 2 | P        |
|             | For non-ferrous metallic and composite conduit systems, the manufacturer provided information about its protection against corrosion                             |              | P        |
| 14.2.2      | Tests for resistance to corrosion for painted and zinc coated steel and steel composite conduits systems   |              | -        |
| 14.2.2.1    | Low protection conduit and conduit fittings inspected for completeness of covering by the protective coating, both inside and outside                            |              | N/A      |

|           |  |  |          |
|-----------|--|--|----------|
| 14.2.2.2  | Test for medium protection conduit and conduit fittings: after completion of the test, the samples showed no more than two blue coloured spots on each square centimetre of the surface, and no blue spot had a dimension larger than 1,5 mm             |  | P        |
| 14.2.2.3  | Test for high protection conduit and conduit fittings: after the test, the sample showed no precipitation of copper which cannot be scrubbed off in running water, if necessary after immersion for 15 s in a 10% solution of hydrochloric acid in water |  | N/A      |
| <b>15</b> | <b>ELECTROMAGNETIC COMPATIBILITY</b>   |  | <b>P</b> |
| 14.1.1    | Products covered by this standards are, in normal use, passive in respect of electromagnetic influences (emission and immunity)  |  | P        |

| ANNEX 1  |                | TABLES   |                                |                                  |                              |                   |          |
|--|----------------|--|--------------------------------|----------------------------------|------------------------------|-------------------|----------|
| <b>8.1</b>   |                | <b>TABLE: dimension</b>  |                                |                                  |                              |                   | <b>P</b> |
|  |                | Reference Table 2 IEC 60423 - Outside diameters for non-threadable conduit |                                | Reference table 102 IEC 61386-21 |                              |                   |          |
| Outside diameters (mm)   | Tolerance (mm) | Measured (mm)  | Maximum entrance diameter (mm) | Measured (mm)                    | Minimum junction length (mm) | Measured (mm)     | Verdict  |
| 6  | +0,0<br>-0,1   |  | 6,5                            |                                  | 6                            |                   | -        |
| 8  | +0,0<br>-0,2   |  | 8,5                            |                                  | 8                            |                   | -        |
| 10   | +0,0<br>-0,2   | 9,93   | 10,5                           | 10,1                             | 10                           | 12,0              | P        |
| 12   | +0,0<br>-0,3   |  | 12,5                           |                                  | 12                           |                   | -        |
| 16   | +0,0<br>-0,3   | 15,98  | 16,5                           | 16,1                             | 16                           | 20,0              | P        |
| 20   | +0,0<br>-0,3   | 19,95  | 20,5                           | 20,2                             | 20                           | 22,0              | P        |
| 25   | +0,0<br>-0,4   |  | 25,5                           |                                  | 25                           |                   | -        |
| 32   | +0,0<br>-0,4   |  | 32,6                           |                                  | 30                           |                   | -        |
| 40   | +0,0<br>-0,4   |  | 40,7                           |                                  | 32                           |                   | -        |
| 50   | +0,0<br>-0,5   |  | 50,8                           |                                  | 42                           |                   | -        |
| 63   | +0,0<br>-0,6   |  | 63,9                           |                                  | 50                           |                   | -        |
| 75   | +0,0<br>-0,7   |  | 75,9                           |                                  | 50                           |                   | -        |
| <b>10.2</b>  |                | <b>TABLE: compression test</b>   |                                |                                  |                              |                   | <b>P</b> |
|  |                | compression force (N)  | <b>1250</b>                    |                                  |                              |                   | -        |
|  |                | tolerance 0, +4%   | max force admitted (N)         |                                  | <b>1300</b>                  |                   | -        |
| size   | n° of sample   | Øi   | Ød                             | Øi - Ød                          | Øi - Ød <25%                 | no visible cracks | Verdict  |
| 10   | 1              | 9,95   | 10,99                          | 1,04                             | P                            | no                | P        |
| 10   | 2              | 9,95   | 10,97                          | 1,02                             | P                            | no                | P        |
| 10   | 3              | 9,97   | 11                             | 1,03                             | P                            | no                | P        |
| 16   | 1              | 15,98  | 17,23                          | 1,25                             | P                            | no                | P        |
| 16   | 2              | 15,99  | 17,31                          | 1,32                             | P                            | no                | P        |
| 16   | 3              | 15,98  | 17,29                          | 1,31                             | P                            | no                | P        |
| 20   | 1              | 19,96  | 20,51                          | 0,55                             | P                            | no                | P        |
| 20   | 2              | 19,95  | 20,48                          | 0,53                             | P                            | no                | P        |
| 20   | 3              | 19,95  | 20,55                          | 0,6                              | P                            | no                | P        |
| Supplementary information  |                |  |                                |                                  |                              |                   |          |
| Øi outside diameter measured before test                         |                |  |                                |                                  |                              |                   |          |
| Ød outside diameter measured during the application of the force |                |  |                                |                                  |                              |                   |          |

| 10.3 |                       | TABLE: impact test     |                   |  |                   | P                                  |         |
|------|-----------------------|------------------------|-------------------|--|-------------------|------------------------------------|---------|
|      | Test temperature (°C) | <b>-45</b>             |                   |  |                   | -                                  |         |
|      | Mass of hammer (kg)   | <b>2</b>               |                   |  |                   | -                                  |         |
|      | tolerance 0, +1%      | max mass admitted (kg) |                   | <b>2,02</b>                                  |                   | -                                  |         |
|      | Fall height (mm)      | 300                    |                   |  |                   | -                                  |         |
|      | tolerance ±1%         | mix height             |                   | <b>297</b>                                   |                   | max height <b>303</b>              |         |
| size | n° of sample          | check with gauge       |                   | No sign of disintegration / no visible crack |                   | Total n° of sample passed the test | Verdict |
|      |                       | n° of sample pass      | n° of sample fail | n° of sample pass                            | n° of sample fail |                                    |         |
| 10   | 1-12                  | 12                     | 0                 | 12   | 0                 | 12                                 | P       |
| 16   | 1-12                  | 12                     | 0                 | 12   | 0                 | 12                                 | P       |
| 20   | 1-12                  | 12                     | 0                 | 12   | 0                 | 12                                 | P       |



**ANNEX 2** | **PHOTO DOCUMENTATION**





earth continuity system

end of photo

| ANNEX 3           |                             | LABORATORY EQUIPMENTS |                   |               |                             |                      |
|-------------------|-----------------------------|-----------------------|-------------------|---------------|-----------------------------|----------------------|
| code              | type                        | manufacturer          | model             | serial        | certificate of calibration  | calibration due date |
| LAB008            | electrical safety tester    | Schleich              | GLP2-i            | 2347          | LAT 238 0714CT-22           | 22/09/2023           |
| LAB021            | torque srewdriver           | Fervi                 | 0806/020          | Q70600255     | T2i 2690/22-2805/22-2806/22 | 28/10/2023           |
| LAB022            | dynamometer                 | Sauter                | FH2K              | 5B15L01144    | T2i 2689/22                 | 27/10/2023           |
| LAB025            | vernier caliper             | Metrica               | vernier caliper   | SC 2927       | LAT 137 S1474/22            | 27/10/2023           |
| LAB058            | ambient datalogger          | Testo                 | Saveris 2 H1      | 0054737942    | LAT 238 0537-22             | 15/02/2024           |
| LAB064+<br>LAB065 | dynamometer                 | AEP                   | TCE-TM25kN + DF12 | 164162 + 6962 | 03214 23 I + 03216 23 I     | 16/01/2025           |
|                   | Petrolium spirit (n-Hexane) | Merck                 | 1.04374.1000      | K54108474     | coa K54108474               | 2027                 |

**END OF REPORT**